

December 12, 2022

Le Monde French Immersion Public Charter School

Summary of Radon Measurement Screening at 2044 E Burnside, Portland, OR 97214

We performed a long-term Radon Measurement screening at the above-referenced address from 10/27/2022 11:30 AM to 12/08/2022 8:00 AM. The testing was conducted in each relevant room of the school. These test results represent the conditions that existed with respect to weather and also operating conditions of the building during the time period tested.

The Smart Radon Monitor "Wave Radon" (Airthings) was utilized for this testing procedure.

Results of the radon testing are included in the table below:

Over the time period of 10/27/22 to 12/08/22 (41 days):	
Average (pCi/L)	0.6
Minimum (pCi/L)	0.0
Maximum (pC/L)	2.0

The overall average for this test is 0.6 pCi/L (picoCuries per Liter). Based on these levels no immediate action is required.

According to the EPA, it is recommended to perform a short-term or long-term radon test at least once every two years. For more information, please refer to the <u>United States Environmental Protection Agency</u>.